

FAILED CHECK REPORT

Emergency light test failed

Riverside Leisure - FICTIONAL DEMO - Riverside Centre

Completed by Sam Parker (demo@example.invalid)

Work date: 2026-08-27 Submitted: 27/08/2026, 11:21:00

1 FAILED CHECK INCLUDED

01 Does the emergency light illuminate during its test?**FAIL****DETAILS**

DEMONSTRATION: AI-generated example photo, not real evidence. Light outside Studio 2 remained off. Maintenance ticket M-1842 raised; duty manager informed. Exact location: First-floor corridor, outside Studio 2; emergency luminaire EL-012. Inspection method: Duty manager operated the local test key and observed the unit during the scheduled functional test. Adjacent corridor lighting was working. Expected result: The emergency luminaire illuminates when the test is activated. Observed result: The diffuser remained dark during the test. The defect was recorded and referred for competent electrical inspection; the cause has not been confirmed. Immediate action: Sam notified Alex Morgan, logged maintenance ticket M-1842 and requested an assessment of the affected route before normal use continued. Follow-up plan: Electrical contractor to inspect supply, battery and lamp, record corrective work and complete a documented retest. Verification required: Alex Morgan to review the contractor record and successful retest before closing the issue. Action owner: Alex Morgan. Current status: Open; contractor inspection pending.

Photo evidence - emergency-light-generated-demo.jpg